

	Q1	Q2	Q3	Q4	Q5	ZM
TR1,TR2	1	1	0	1	0	1
AWARIA TR2	1	0	1	0	0	1
AWARIA TR1	0	1	0	0	0	1
BRAK ZAS.	0	0	0	0	1	0

The diagram shows two power transformers, T1 and T2, connected to a common busbar. Each transformer has a rating of 1600kVA and 15kV/0,4kV. The primary windings are connected to the busbar, and the secondary windings are connected to a common busbar labeled 'Szynoprzewód 2500A'.

	Q31	Q32
zasil. z TR1, TR2	0	1
zasil. z TR1	1	0
zasil. z TR2	0	1
brak zasilania	0	0

E-10